

Evidence of Performance

Resistance to wind load
Watertightness, Air permeability
Operating forces, Load-bearing capacity of
safety devices



Test Report 102 34194/1e (ITT)

Translation of Test Report 102 34194/1 dated 17 September 2007

Client **FIRAT PLASTIK VE KAUCUK A.S.**
Türkoba Koyü P.K.
12 Büyükçekmece

Istanbul
Turkey

Bases

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06


EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11

EN 14609 : 2004-03

Representation



Product	Single tilt and turn window
Designation	F7060
Overall dimensions (W x H)	750 mm x 1500 mm
Frame material	PVC-U / white
Special features	-/-

Instructions for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1 : 2006-03. For the sake of clarity it may be used as the basis for the ITT report summary by the manufacturer in the framework of the attestation of conformity procedure 3 as the basis for the manufacturer declaration.

Validity

The data and results refer solely to the tested and described specimen.

Subject to compliance with the relevant casement weights, the test results can be extrapolated for constructions of identical or smaller dimensions of the same design, type of rebate and similar format.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift test Documents" applies..

The cover sheet can be used as abstract.

Contents

The report contains a total of 9 pages.

Resistance to wind load – EN 12210



Class C3/B3

Watertightness – EN 12208



Class 8A

Air permeability – EN 12207



Class 4

Operating forces – EN 13115



Class 1

Load-bearing capacity of safety devices



Requirement fulfilled

ift Rosenheim
17 October 2007


Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades


Benno Reichelt, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Giell-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkante PUZ-Stelle: BAY 18

DAP-PL-0908 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60